



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-5126BL0564

Registration Number
Registriernummer

Field of Application
Anwendungsbereich

products of gas supply
Produkte der Gasversorgung

Owner of Certificate
Zertifikatinhaber

[REDACTED]

Distributor
Vertreiber

[REDACTED]

Product Category
Produktart

Greasing and sealing materials: Sealing material and HTB resistant seals for the gas installation (5117)

Product description
Produktbezeichnung

Flat sealing material based on graphit for pressure regulators and rotary displacement gas meters, higher thermic chargeable

Model
Modell

Grafilit® SP

Test reports
Prüfberichte

Laboratory control test: 21-00588-KP04 from 15.03.2023 (EBI)

Test basis
Prüfgrundlagen

DIN 30653 (01.08.2018)

Date of Expiry / File No. 08.12.2030 / 23-0623-GNV
Ablaufdatum / Aktenzeichen



08.02.2024 Koh A-1/2

i. A. D. 72

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
Grafilit® SP	Max. operating pressure: 5 bar	

certified Components**zertifizierte Bauteile / Werkstoffe**

Registr. No. Registrier-Nr.	Component Bauteil (Produktart)	Model/Type Modell/Typ	Manufacturer Hersteller
NG-5124BL0368	Flat sealing materials on graphit basis	Grafilit SP/Grafilit SP	DONIT TESNIT d.o.o.

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

Field of application for pressure range ≤ 1 bar: unions and flanges for gas meters and pressure regulators according to DIN 3376-1, DIN 3376-2, DIN 2993 and DIN EN 10242

Field of application for pressure range ≤ 5 bar: flanges for pressure regulators and rotary piston gas meters according to DIN 2543, DIN 2633, DIN EN 1092-1 and DIN EN 1092-2

