



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-5126BL0564

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	DONIT TESNIT d.o.o. Cesta komandanta Staneta 38, SLO-1215 Medvode
Distributor <i>Vertreiber</i>	DONIT TESNIT d.o.o. Cesta komandanta Staneta 38, SLO-1215 Medvode
Product Category <i>Produktart</i>	greasing and sealing materials: Flat sealing materials for gas installation, with higher thermal resistance (5126)
Product Description <i>Produktbezeichnung</i>	Flat sealing material based on graphit for pressure regulators and rotary displacement gas meters, higher thermic chargeable
Model <i>Modell</i>	Grafilit® SP
Test Reports <i>Prüfberichte</i>	laboratory control test: 18/039/5126/02 from 22.03.2018 (EBI)
Test Basis <i>Prüfgrundlagen</i>	DIN 30653 (01.08.2018)

70028-DI-A-DE

Date of Expiry / File No. 08.12.2023 / 19-0252-GNU
Ablaufdatum / Aktenzeichen

20.05.2019 Fi A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type	Technical Data	Remarks
<i>Typ</i>	<i>Technische Daten</i>	<i>Bemerkungen</i>
Grafilit® SP	max. operating pressure: 5 bar	

certified Components**zertifizierte Bauteile / Werkstoffe**

Registr. No.	Component	Model/Type	Manufacturer
<i>Registrier-Nr.</i>	<i>Bauteil (Produktart)</i>	<i>Modell/Typ</i>	<i>Hersteller</i>
NG-5124BL0368	Flat sealing materials on graphit basis	Grafilit SP/Grafilit SP	DONIT TESNIT d.o.o.

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

Field of application for pressure range ≤ 1 bar: unions and flanges for gas meters and pressure regulators according to DIN 3376-1, DIN 3376-2, DIN 2993 and DIN EN 10242

Field of application for pressure range ≤ 5 bar: flanges for pressure regulators and rotary piston gas meters according to DIN 2543, DIN 2633, DIN EN 1092-1 and DIN EN 1092-2