



DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DG-5126BS0072

Registration Number
Registriernummer

Field of Application
Anwendungsbereich

products of gas supply
Produkte der Gasversorgung

Distributor
Vertreiber

Otto Haas KG
Gießener Straße 5, D-90427 Nürnberg

Product Category
Produktart

Greasing and sealing materials: Sealing material for HTB resistant seals in the gas installation (5118)

Product description
Produktbezeichnung

Flat sealing materials for gas installation, with higher thermal resistance

Model
Modell

OHA-Press®

Test reports
Prüfberichte

Type testing: 164889T0/18167 from 11.04.2022 (GWI)
Supplement test: 23-00007-AB01 from 28.08.2023 (EBI)

Test basis
Prüfgrundlagen

DIN 30653 (01.08.2018)

Date of Expiry / File No. 25.01.2027 / 25-0227-GNR
Ablaufdatum / Aktenzeichen

70028-04-A-DE

20.05.2025 Fi B-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

P. Schmidt



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-00

DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dvgw-cert.com
www.dvgw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
OHA-Press®	Pressure range: 0,1/1,0/5,0 bar	depending on the area of application

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

Field of application: screw connections for gas meters according to DIN 3376-2 (one-pipe-connection), screw connection according to DIN 2993 respectively DIN EN 10242 until 0,1 bar

Field of application: flange connection according to DIN EN 1092-1 and DIN EN 1092-2, 0,1 until 5,0 bar
HTB resistant.

