## **Flood Barrier**

## **OHA-Flood Barrier DN 50**

with PP-Siphon, closeable, Backwater double and emergency closure

#6701





The *Flood Barrier*, (backwater valve acc. to DIN EN 13564 Type 5) for Faecal-free wastewater with two self-contained closures and an emergency stop prevents backflow of the dirty water in the event of backwater, whereby the emergency stop can be manually operated and locked. *The maintenance* is acc. to DIN EN 13564 two times yearly be carried out by qualified personnel, in addition, the barrier must be cleaned and any defective parts replaced.

## **ATTENTION:**

- It must be ensured that the OHA blocking device is installed straight and without tension. When installing, observe the "flow direction".
- Before using a spiral, the locking mechanism must be removed!
- In the event of backflow, considerable pressure can build up in the piping system and affect the body. This can lead to a pressing out of the barrier from the drain line. In order to prevent this, the locking mechanism must be additionally fastened.

























